



TOWN OF RANDOLPH, VERMONT

1/24/2023

Boil Water Has Been Lifted!

Attention Randolph Village resident,

The Boil Water order has been lifted!!!! Per state regulations the state required *Two* samples from the affected area to be absent of both E.coli and Coliform bacteria. We collected *Two* samples yesterday morning January 23rd, 2023 and received the results this morning that we are clear of possible contaminants. See back of this page for test results.

So just to be clear, the areas affected were South Pleasant street, Fairview, Verona, Edgewood, and Pearl St. The Boil water order has been lifted!

Thank you all for your patience and understanding during this situation.

Chris Chambers
Randolph Village Water Superintendent

Laboratory Report



Randolph Municipal Office 071211
 Water System
 Drawer B
 Randolph, VT 05060
 Atten: Chris Chambers

PROJECT: WSID 5179 Randolph TC SP
 WORK ORDER: **2301-02160**
 DATE RECEIVED: January 23, 2023
 DATE REPORTED: January 24, 2023
 SAMPLER: Tony Delegato **VT0005179**

001 Site: WSID 5179, 58 South Pleasant St - SYSTEM EVALUATION Date Sampled: 1/23/23 Time: 10:25

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: SP Compl Ind: N Repl Ind: N

Free Chlorine Residual (Field Result): .57 ppm

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Total Coliform	ABSENT	/100 mL	SM20 9223B Colilert	1/23/23 13:42	R LPJ	A	
E. coli	ABSENT	/100 mL	SM20 9223B Colilert	1/23/23 13:42	R LPJ	A	

002 Site: WSID 5179, 9 Fairview St - SYSTEM EVALUATION Date Sampled: 1/23/23 Time: 10:50

Facility ID: DS001 Smp Pt: TC001 Categ: TC Smp Type: SP Compl Ind: N Repl Ind: N

Free Chlorine Residual (Field Result): .08 ppm

Parameter	Result	Units	Method	Analysis Date/Time	Lab/Tech	NELAC	Qual.
Total Coliform	ABSENT	/100 mL	SM20 9223B Colilert	1/23/23 13:42	R LPJ	A	
E. coli	ABSENT	/100 mL	SM20 9223B Colilert	1/23/23 13:42	R LPJ	A	

Endyne will submit this data electronically to the State of VT Water Supply Division in accordance with their policy and standards.

The column heading "Lab" denotes the laboratory facility where the testing was performed. "W" designates the Williston, VT lab under NELAC certification ELAP 11263; and ISO/IEC 17025:2017 accredited "R" designates the Lebanon, NH facility under certification NH 2037. This analysis meets NELAC requirements except as noted. Test results are representative of the samples as they were received at the laboratory. Chlorine field results are provided by the client unless otherwise indicated.

Reviewed by:

Alexander J Rakotz
 Laboratory Director Lebanon, NH

www.endynelabs.com



160 James Brown Dr., Williston, VT 05495
 Ph 802-879-4333 Fax 802-879-7103

56 Etna Road, Lebanon, NH 03766
 Ph 603-678-4891 Fax 603-678-4893

